

**DLH 6 R SH 23 Y ICA**
6" IC-Rated LED

Remodel Shallow Housing
120-277V

Listings

- UL Listed for Damp Locations
- UL Listed for Feed Through
- Certified under ASTM-E283 for Air Tight Construction

**Descriptions**



The Luminoso 6" dedicated LED IC Remodel Shallow housing is designed for remodel applications and suitable for direct contact with insulation in ceiling. Remodel Housing may be installed from below the ceiling. Great for use in shallow ceiling which have tighter clearance. The air tight construction reduces energy costs by preventing air flow between occupied conditioned spaces and non-vented areas.

Junction Box

- Designed to accommodate conduit runs.
- Contains one 1/8", six 7/8" knockouts and four conduit pryouts with strain relief.

Remodel Clips

- Four remodel clips secure housing and accommodate 1/2" and 5/8" ceiling material.

Dimensions



Recessed Downlight

WARNING : These products may represent a possible shock or fire hazard if improperly installed or attached in any way. Products should be installed in accordance with these instructions, current electrical codes and/or the current National Electric code (NEC).

CAUTION – To reduce risk of fire, electric shock or injury to persons:

1. Make sure that the electrical power to the fixture is disconnected prior to any installation or retrofit.
2. This light is suitable for damp locations.

WARNING : Risk of fire or electric shock. Installation requires knowledge of recessed lighting luminaires electrical systems. If not qualified, do not attempt installation. Contact a qualified electrician.

Do not use these products in luminaires located where elevated ambient temperatures exist.

WARNING : Risk of fire or electric shock. The installer must determine whether power supply is 120V AC before installation. (120V/277V Ac 50~60Hz is available if 120V/277V is indicated on caution label)

WARNING : Risk of fire or electric shock. Luminaire's wiring, ballast(s), or other electrical parts may be damaged when drilling for installation of reflector kit hardware. If drilling is required in any installation, check for enclosed wiring and components and be careful to protect them from any harm. To prevent wiring damage or abrasion, do not expose wiring to edges of sheet metal or other sharp objects.

THIS PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH THE APPLICABLE INSTALLATION CODE BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT AND THE HAZARDS INVOLVED.